

A bid opening was conducted on June 18, 2024, in the Town of Moreau Municipal building, 351 Reynolds Road, Moreau, New York, for the Bluebird Pump Station Upgrade.

The Deputy Town Clerk started the bid opening at 9:00 a.m.

Present

Dianne Lewis Deputy Town Clerk
John Donohue, Jr. Councilmember

The following notice to bidders appeared in the legal ad section of the Saratogian newspaper on June 13, 2024:

NOTICE TO BIDDERS

NOTICE IS HEREBY GIVEN that the Town of Moreau is accepting bids for the upgrade of the Bluebird Village pump station in accordance with the specifications on file with the Moreau Town Clerk at the address listed below.

The Moreau Town Clerk will receive the sealed proposals at the Moreau Town Hall located at 351 Reynolds Rd, Fort Edward, NY 12828, until **9:00 AM on Tuesday, June 18, 2024** and will then be publicly opened and read aloud. The Moreau Town Clerk will then submit the Bids to the Town Board for consideration and approval, if any, at its next regularly scheduled meeting.

The right is reserved to reject any or all Bids, waive any informalities, and accept any bids considered advantageous to the Town of Moreau.

No proposal may be withdrawn, without the consent of the Town Board, for 45 days after the time for opening bids has passed.

Specifications for the work to be done are as follows, and complete bid documents may be examined and obtained at the Town Clerk's office at 351 Reynolds Rd, Fort Edward, NY 12828, during regular weekday business hours until **9:00 AM on Tuesday, June 18, 2024**.

The project generally consists of the following work:

- Bypass the wet well to avoid interruption of service, with adequate pump.
- Remove (2) existing 3hp Landustrie pumps.
- Remove existing guiderail system and base elbows.
- Plan to reuse the existing base elbow system with guiderails, as the larger pumps use the same Landy coupling/adapter system as the existing.
- Removing existing 33"x33" access hatch, cut a larger opening in the concrete and install a 36"x36" access hatch. Final measurements would be required as the space in that area of the station is limited.
- Reinstall guiderail system with base elbow system to larger hatch opening.
- Modify/Move/Rework the discharge piping (4" PVC SCH80), reconnect to existing above ground header. This may require widening the hole in the concrete, that the existing discharge pipe is fed though, inside a green fiberglass enclosure to connect to header.
- Install (2) new 20hp Landustrie pumps.
- Provide and install new Duplex control panel. If unable to install inside the fiberglass enclosure, where the old Gorman Rupp panel is currently located, a weather rated panel would be required, if outside installation is necessary.
- The successful Bidder may utilize the existing mounting stand, that the Aqualogic panel is installed on. However, that will be dependent on new panel dimensions.
- Site restoration.

Proposals must be made upon, and in accordance with, the form of the proposal included with the bid documents, prepared for this solicitation. The formal proposal contains a Notice to Bidders, Instructions to Bidders, an Affidavit of Non-Collusion, Certification of Compliance with the Iran Divestment Act, a

A bid opening was conducted on June 18, 2024, in the Town of Moreau Municipal building, 351 Reynolds Road, Moreau, New York, for the Bluebird Pump Station Upgrade.

Bid Proposal, and Bid Specifications. All statements and requirements of this advertisement, Bid Proposal, Instruction to Bidders, Certification of Compliance with the Iran Divestment Act, and the Affidavit of Non-Collusion shall be deemed a part of the Contract to Purchase entered into by the Town, with the successful Bidder.

An email copy of the Bid Documents may be requested by calling the Town Clerk's office at 518-792-1030 or by emailing townclerk@townofmoreau.org.

Publication Date: June 13, 2024

Erin Trombley, Town Clerk

Town of Moreau

The following bids were received, opened, and read aloud:

Emerick Associates, Inc 1107 Loudon Rd Cohoes, NY 12047	\$74,500.00
---	-------------

The bid results were forwarded to the Town Board, for review and discussion at the Special Town Board meeting on June 18, 2024 at 9:30 a.m.

The bid opening concluded at 9:01 a.m.

Respectfully submitted,

Dianne Lewis
Deputy Town Clerk